Office of the Dy. Executive Engineer
Date 01-10-26

GOVERNMENT OF ANDHRA PRADESH
PANCHAYAT RAJ ENGINEERING DEPARTMENT
PRI SUB DIVISION, ETCHERLA.

From
T. Samuel Raju, B.Tech.
Deputy Executive Engineer
PRI Sub Division, Etcherla

To
The Chairman
Keshava Reddy EM School.
Etcherla, Srikakulam

Rc.No.01/JTO/2026, Dt.01.10.2026.

Sir,

Sub: PRED- PRI Sub-Division, Etcherla – Verification of soundness of the building for safety of Keshava Reddy EM School at Etcherla - report furnished – Regarding.

Ref: Lr.No. Dt. 20-09-2026, AGM, Keshava Reddy EM school, Etcherla

*****

This is certified that the existing building Keshava Reddy EM School at Etcherla (Village & Mandal) Srikakulam (District) -532410 is having one block of Ground + 3 floors. This block G+3 floors are physically verified on 01-10-2026.

The building each floor is verified and observed that there are no spalling of ceiling and also no cracks found on the columns. The framed structure is intact and observed in all the G+3 floors of Keshava Reddy school at Etcherla.

The building owned by the Keshava Reddy School at Etcherla have complied with the building soundness requirements in accordance with the National Building Code of India 2005 rules and verified the building in presence of Sri T.Chandra Sekhar Reddy, Etcherla, Srikakulam and the building is fit for occupancy of running school with effect from 01-10-2026 for a period of two (2) years in accordance with rule and subject to compliance of the specific conditions as appended. The Management has to conduct time to time maintenance and also to conduct NDT and UPV tests with certified structural engineer for this building.

Yours faithfully,
1/10/26
Dy. Executive Engineer
PRI Sub Division, Etcherla.

Office of the Dy. Executive Engineer
Date 01-10-26
PRI Sub Division ETCHERLA

MANAGER
Keshava Reddy E M School
Etcherla, Srikakulam-410

PRINCIPAL
Keshava Reddy EM School
Etcherla, Srikakulam-410